

9/12/17 @ 9AM

Street #	Street Name	Test Result 9/12/17
3090	WEDGEWOOD ROAD	No One home but vents in roof had smoke coming out of it
3093	WEDGEWOOD ROAD	No One home but vents in roof had smoke coming out of it
3097	WEDGEWOOD ROAD	No One home but vents in roof had smoke coming out of it
3100	WEDGEWOOD ROAD	Vent Working but two clean outs in front yard are leaking, this is down by ditch area
3115	WEDGEWOOD ROAD	1 vent working correctly but the other one vents into eves
3131	WEDGEWOOD ROAD	All Good No Issues
3132	WEDGEWOOD ROAD	All Good No Issues
3139	WEDGEWOOD ROAD	All good inside but clean out in front yard is broken and leaks
3144	WEDGEWOOD ROAD	No one home but vents in roof did not have smoke coming out of it
3281	WEDGEWOOD ROAD	2 vent pipes both cut below roofline. One venting into eaves other no smoke
3304	WEDGEWOOD ROAD	No One home but vents in roof had smoke coming out of it
3311	WEDGEWOOD ROAD	No one home smoke coming out vents
3315	WEDGEWOOD ROAD	No one home smoke coming out vents
3324	WEDGEWOOD ROAD	No one home and vents don't work
3325	WEDGEWOOD ROAD	Clean out cap broken in driveway, main line in basement/garage leaking, washer hook needs to be fixed, far west roof vent does not work

Street #	Street Name	Test Result 9/12/17
3341	WEDGEWOOD ROAD	1st floor wash basin had smoke in it put water in it and the smoke went away, they need to make sure the trap has water in as they never use it
3360	WEDGEWOOD ROAD	No smok in house, vents work
3366	WEDGEWOOD ROAD	Smoke coming from eves front left corner, vent issues
3370	WEDGEWOOD ROAD	clean out in front yard near road broken off, smoke coming from it very bad leak
3378	WEDGEWOOD ROAD	All good but has a broken clean out cap in back yard
3381	WEDGEWOOD ROAD	All good in house vent working
3401	WEDGEWOOD ROAD	No smoke from vents and no one home
3404	WEDGEWOOD ROAD	All Good
3460	WEDGEWOOD ROAD	All Good
2269	COUNTY RTE 17	No one home, smoke coming from clean out in yard